

UCMR3 Sampling Results

DETECTED CONTAMINANTS	Unit	MCL ¹	PHG or (MCLG)	Range	Average	Typical Sources in Drinking Water
Chlorate	ppb	800 (NL)	NA	120 - 160	140	Degradation of disinfectant
Chromium-total ²	ppb	50	-100	<0.2 - 0.11	<0.2	Erosion of natural deposits; industrial discharges
Chromium-6 ³	ppb	10	0.02	<0.03 - 0.09	0.09	Erosion of natural deposits; industrial discharges
Strontium	ppb	NA	NA	15 - 22	18	Erosion of natural and pipe deposits
Vanadium	ppb	50 (NL)	NA	<0.2 - 0.48	<0.2	Erosion of natural and pipe deposits